



MUNICIPAL CORPORATION OF DELHI  
(Office of Dy. Health Officer: Rohini Zone)  
Public Health Department  
Sector 5 Rohini Delhi -110085  
Email: [dhoroheinizone15@gmail.com](mailto:dhoroheinizone15@gmail.com) Tel: 011-27052106

No.-DHO/RZ/2022/167

Date : 27/06/22

### SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Astt. Public health Inspector from Public Health department Rohini Zone inspected the **BAL VIDYA MODEL SCHOOL SITUATED AT B-247, LAXMI PARK, NEAR NARAYAN DHARM KANTA, NANGLOI, NEW DELHI-110041** and found that the **BAL VIDYA MODEL SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from the date of issue.

  
Dy. Health Office  
Rohini Zone

**Principal**  
**BAL VIDYA MODEL SCHOOL**  
**B-247, LAXMI PARK, NEAR NARAYAN DHARM KANTA,**  
**NANGLOI, NEW DELHI-110041**


"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"

DELHI JAL BOARD  
( GOVT. OF N.C.T. DELHI )  
QUALITY CONTROL LABORATORY,  
WATER TREATMENT PLANT NANGLOI, DELHI-110041

आज़ादी का  
अमृत महोत्सव

Water sample collected from " Bal Vidya Model Sr. Sec. School" B-247, Laxmi Park, Near Narayan Dharam  
Karia, Nangloi, New Delhi -110041 vide challan No- 48 Dated- 11.05.2023.

S. No	Parameter	Units	Limit		S1
			Acceptable	Permissible	
<b>PHYSICAL EXAMINATION</b>					
1.	Date of collection	-----	--	--	27.05.2023
2.	Date of Analysis	-----	--	--	29.05.2023
3.	Colour	-----	--	--	Clear
4.	Odour	Hazen	5.0	15	No Obj
5.	Turbidity	-----	No. Objectionable		No Obj
6.	PH value	N.T.U.	1.0	5.0	0.94
7.	Electrical Conductivity	-----	6.5	8.5	7.0
8.	Total dissolved solids	µmho	--	--	90
<b>CHEMICAL EXAMINATION</b>					
9.	P <sup>H</sup> Alkalinity	mg/l	500	2000	58.5
10.	Total Alkalinity	mg/l	--	--	NIL
11.	Total Hardness	mg/l	200	600	18
12.	Calcium Hardness	mg/l	200	600	26
13.	Magnesium Hardness	mg/l	--	--	14
14.	Calcium as Ca	mg/l	--	--	12
15.	Magnesium as Mg	mg/l	75	200	5.6
16.	Ammonia as N	mg/l	30	100	2.88
17.	Nitrite as N	mg/l	0.5	N.R.	NIL
18.	Nitrate as NO <sub>3</sub>	mg/l	---	--	NIL
19.	Sulphate	mg/l	45	N.R.	0.8
20.	Chloride	mg/l	200	400	10
21.	Dissolved Iron	mg/l	250	1000	12
22.	Fluoride	mg/l	0.3	N.R.	0.02
23.	Cyanide	mg/l	1	1.5	0.02
24.	Residual Chlorine	mg/l	0.05	N.R.	ND
<b>BACTERIOLOGICAL EXAMINATION</b>					
25.	Coli-form per 100 ml at 37°C	MPN	0	0	0



REMARKS As per tested parameters sample -S1 can be use for drinking purpose

*S. Sanchay*  
Chemist

*[Signature]*  
Principal  
BAL VIDYA MODEL SCHOOL  
LAXMI PARK, NANGLOI

*[Signature]*  
31/5/23  
ACWA  
Asstt. Chief Water Analyst  
DELHI JAL BOARD  
Govt. of N.C.T. Delhi  
Quality Control Laboratory  
Water Works Nangloi, Delhi-41